

CAMP PROPERTY DATA

CONSOLIDATED BPCA: Doe Lake

Immediate Work Required:	Rectify loose and deteriorated brick masonry on the chimney of one building Rectify the irregularity in height of the walkway in one location
Significant Other Work to be Completed Over Next 15 Years:	Replacement of selective sloped asphalt shingled and metal roof systems General repairs to exterior wall systems On-going selective replacement of exterior windows and door systems Replacement of the perimeter window and exterior wall joint sealants Repairs to balcony systems On-going repairs to the foundations and supports of site buildings On-going repairs and replacement of the interior finishes and appliances On-going repairs and replacement of the siture features (pavement, gravel driveway, wood stairs) Replacement of nine forced- air furnaces Replacement of 27 domestic hot water heaters Replacement of selective electrical panels and associated wiring Mid-life overhaul of the emergency electrical generator Replacement of 3 fire alarm panels Rehabilitating the on-site accessibility features to a satisfactory level AODA Compliance
Total Costs Over 15 Years	\$1,280,214